

C.No.299/FSD/FPW/NOC/2025/421

FIRE SAFETY CERTIFICATE


EoDB Application No. : 194076

Dated: 21.06.2025

Certified that the Aditya Vidyashram Residential School at Poraiyur, Villianur, Puducherry comprised of one block of four storeyed building (K G Block), two blocks of five storeyed building (Main & Academic Block) and one block of six storeyed building (Primary Block) owned / occupied by M/s. Aditya Vidyashram Residential School have complied with the Fire Prevention and Fire Safety requirement in accordance with the Codes & Standards and inspected & examined by the officers of the Fire Service Department in the presence of Dr. Nadesan Kanguayan, Principal and that the building /Premises is fit for occupancy up to classes L.K.G to XII for the academic year 2025-2026 from the issue of this certificate in accordance with Codes & Standards and subject to compliance of specific conditions as appended:-

1. To comply fully with the National Building Code of India, 2016 (Part 4 – Fire and Life Safety) and Standards for the present occupancy of the building at the earliest.
2. The Fixed Fire Fighting Installations provided in the building are to be under proper Care & Maintenance as per the Codes & Standards and recorded in registers by employing (24X7) well trained Fire Fighting Crew/Guards.
3. Emergency / Quick Response Team (ERT/QRT) with the above crew along with other Staffs shall be constituted for responding immediately during emergencies for safe & speedy evacuation of the occupants and loss mitigation.
4. The occupant and fire load of the building shall be maintained properly.
5. The Electrical equipment/appliances are to be maintained as per Codes and Standards for the building.
6. To have a total Evacuation Plan / SOP for fire and other emergencies, scheduled Annual time Table / Calendar for Fire Safety Training to the staffs, Table Top Exercise, Mock drill and conduct the same under the supervision of the Fire Service Department.
7. The approved class of occupancy of the building shall not be altered.
8. The Setbacks on all sides, Corridors, Passages, Staircases, Entries and Exits shall always be free of any obstruction for easy movement during any emergency.
9. Any structural addition/alteration in the building shall be made with the prior approval of the Competent Authority and Fire Service Department

Issued on 21.06.2025 at Puducherry.


(K. ILANGO)
DIVISIONAL FIRE OFFICER
PUDUCHERRY

To

M/s. Aditya Vidyashram Residential School,
Poraiyur, Villianur, Puducherry.

